



LOT LINE WINDOW SPRINKLER. INSTALL A WAY THAT DISCHARGE WILL SPRAY ENTIRE GLASS SURFACE

SPRINKLER HEAD COUNT
 45 RESIDENTIAL PENDENT FLUSH SPRINKLER HEADS
 14 RESIDENTIAL HORIZONTAL SIDE WALL SPRINKLER HEADS
 1 HORIZONTAL SIDE WALL SPRINKLER HEAD FOR CHUTE (6TH, 8TH, 10TH FLOOR)
 TOTAL 59 OR 60 SPRINKLER HEADS

LEGEND :-

| | |
|--|---|
| | FIRE PIPE WORK |
| | PENDENT FLUSH SPRINKLER HEAD |
| | RESIDENTIAL PENDENT FLUSH SPRINKLER HEAD |
| | UPRIGHT |
| | RESIDENTIAL HORIZONTAL SIDE WALL SPRINKLER HEAD |
| | HORIZONTAL SIDE WALL SPRINKLER HEAD |
| | EXTENDED COVERAGE HORIZONTAL SIDE WALL SPRINKLER HEAD |
| | GATE VALVE |
| | OS&Y VALVE |
| | ZONE CONTROL VALVE |
| | FLOW SWITCH |
| | TAMPER SWITCH, WIRED BY ELECT. CONTR. |
| | PRESSURE GAUGE |
| | NON RETURN VALVE |
| | CAPPED CONNECTION |
| | DRAIN VALVE |
| | ISOLATING VALVE |
| | SIGHT GLASS |
| | FMUL NON-RISING STEM GATE VALVE |
| | SIAMESE CONNECTION |
| | SOLENOID VALVE |
| | BOP BOTTOM LEVEL OF PIPE FROM FFL |
| | TB TO BELOW |
| | TA TO ABOVE |
| | FA FROM ABOVE |
| | FB FROM BELOW |
| | FCA FLOOR CONTROL VALVE ASSEMBLY |
| | FHV FIRE HYDRANT VALVE |

NOTE TO ARCHITECT OR ENGINEER

THIS DRAWING IS A PRESENTATION OF A PROPOSED LAYOUT. IT IS THE CONTRACTOR'S RESPONSIBILITY TO VERIFY AND REVIEW PRIOR TO FINAL SUBMISSION. CADDSULTANTS IS NOT RESPONSIBLE FOR DISCREPANCY IN THE FIELD. ANY CORRECTIONS TO THE DRAWING IS REQUIRED BY THE CONTRACTOR TO ADVISE CADDSULTANTS BEFORE FINAL SUBMISSION & BEFORE FABRICATION OR INSTALLATION.

| | | |
|-----|----------|--------------------------------------|
| 03 | 09-03-18 | Issued for review after coordination |
| 02 | 08-31-18 | Issued for review after coordination |
| 01 | 03-09-18 | Issued for review |
| NO. | DATE: | DESCRIPTION: |

MECHANICAL CONTRACTOR:
Best Plumbing & Heating, Inc.
 507 Graham Avenue
 Brooklyn, NY 11222
 PH (718) 766-8500

DRAFTING COMPANY:
CADDSULTANTS
 Certified CAD Specialist
 All Types of Drafting
MARC HOFFMAN
 167 Allen Road
 Rockville Centre, NY, 11570
 Contact: 616.641.2512
 Email: Caddsultant@yahoo.com

DRAWING TITLE :
 6TH-11TH FLOOR
 SPRINKLER LAYOUT

PROJECT INFORMATION:
 211 SCHERMERHORN ST.
 BROOKLYN, N.Y 11201