FLAG NOTES

1. GRILLE MOVED OFF OF LIGHTING, ENGINEER TO ADVISE IF NEW LOCATION IS OK
2. PLEASE ADVISE IF SET IS NECESSARY AND CAN DUCT BE RUN AT 10'-2" BY NOTCHING 2" OFF OF BEAM.
3. DRAWING CALL FOR A DIFFERENT INTAKE DIAMETER THAN THE EQUIPMENT SUBMITTAL. DRAFTER FOLLOWED THE SUBMITTAL FOR INLET SIZE. PLEASE ADVISE.
4. NOT ON THIS SHEET
5. POSSIBLE CONFLICT W/ LIGHTING

DUCT IN NON-EXPOSED AREAS ARE ACOUSTICALLY LINED 15 FT. FROM UNITS.
ALL EXPOSED DUCT IS ACOUSTICALLY LINED.
DIMENSIONS ON DRAWING INCLUDE A.L. & ARE OUTSIDE DIMENSIONS.

LOW PRESSURE DUCT BRANCES TO BE RUN IN BEAM POCKETS OVER TOP OF HIGH PRESSURE DUCT MAINS VERIFY IN FIELD EXACT LOCATIONS & RISES NEEDED

BOTTOM OF DECK +11'-8"

NOTE TO ARCHITECT OR ENGINEER

THIS DRAWING IS A REPRESENTATION OF A PROPOSED LAYOUT. IT IS THE CONTRACTORS RESPONSIBILITY TO VERIFY AND REVIEW PRIOR TO FINAL SUBMISSION. CADSULTANTS IS NOT RESPONSIBLE FOR DISCREPANCY'S IN THE FIELD. ANY CORRECTIONS TO THE DRAWING IS REQUIRED BY THE CONTRACTOR TO ADVISE CADSULTANTS BY A RED-LINED SKETCH OF VERBAL DESCRIPTION FOR FINAL SUBMISSION INCLUDE FABRICATION & INSTALL. ANY CHANGE FROM ORIGINAL DESIGN, FABRICATION & INSTALL WITHOUT CONSULTANTS ADDITIONAL COSTS FOR RE-DRAFTING SUCH AS CHANGE ORDERS, ASBUILT CHANGES, EQUIPMENT CHANGE OUT OR RELOCATIONS. ADDITIONAL SURVEY MAY BE NECESSARY. CADSULTANTS IS NOT RESPONSIBLE FOR ANY BACK CHARGES.

NO.	DATE:	DESCRIPTION:
1	06/10/19	FOR APPROVAL

REVISIONS

MECHANICAL CONTRACTOR:

AP MECHANICAL LLC
5 WAREHOUSE LANE
SUITE 160
ELMSFORD, NY 10523

DRAFTING COMPANY:

Professional Drafting Services
Certified / Insured CAD Specialists
Marc W. Hoffman
CADSULTANTS LLC
167 Allen Road
Rockville Centre NY, 11570
Contact: 646.643.2532
Email: Cadsultant@mail.com

DRAWING NAME:

8TH FLOOR
SHEET METAL PLAN

PROJECT INFORMATION:

136 MADISON AVENUE
8TH FLOOR
NEW YORK, NY 10016

Drawn by: MLB	Checked by: MH	Page no:
Scale: 3/8"=1'-0"	Date: 06/10/19	Drawing Number
PAGE-36x48		M-100B

8TH FLOOR - SHEET METAL PLAN

SCALE: 3/8" = 1-0"